



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6222	8.0	Upright	SR	5 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6322	8.0	Upright	QR	3 mm	3/4	Brass, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2001, 2043

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D. B. Fuller', written over a horizontal line.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6212	8.0	Pendent	SR	5 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6212	8.0	In-Rack Pendent	SR	5 mm	3/4	Brass, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6212	8.0	Recessed Pendent	SR	5 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2001, 2015, 2005, 2043
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6312	8.0	Pendent	QR	3 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA6312	8.0	In-Rack Pendent	QR	3 mm	3/4	Brass, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA6312	8.0	Recessed Pendent	QR	3 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2001, 2015, 2005, 2043

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads "D. B. Fuller".

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Sprinkler Guards for Automatic Control Mode Sprinklers for Fire Protection

Model	Type	Sprinklers FM Approved with	Sprinkler Type
C-1	Guard	RA6212, RA6222, RA6312, RA6322	Upright and pendent automatic sprinklers
C-3	Guard/Shield	RA6222, RA6322	Upright automatic sprinklers
C-5	Guard/Shield	RA6212, RA6312	Pendent automatic sprinklers

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2091
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', written over a horizontal line.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group