



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6412	8.0	Pendent	SR	5 mm	3/4	Stainless Steel Alloy 316L	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6412	8.0	Recessed Pendent	SR	5 mm	3/4	Stainless Steel Alloy 316L	135, 155, 175, 200 (57, 68, 79, 93)
RA6414	5.6	Pendent	SR	5 mm	1/2	Stainless Steel Alloy 316L	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6414	5.6	Recessed Pendent	SR	5 mm	1/2	Stainless Steel Alloy 316L	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2042, 2017, 2001, 2015

FM Approval Standard: Select the FM Approvals Standard

Approval Identification: 3056839

Approval Granted: January 17, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6422	8.0	Upright	SR	5 mm	3/4	Stainless Steel Alloy 316L	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6424	5.6	Upright	SR	5 mm	1/2	Stainless Steel Alloy 316L	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657, USA

FM Approvals Class: 2042, 2016, 2001

FM Approval Standard: Select the FM Approvals Standard

Approval Identification: 3056839

Approval Granted: January 17, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6512	8.0	Pendent	QR	3 mm-XS	3/4	Stainless Steel Alloy 316L	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA6512	8.0	Recessed Pendent	QR	3 mm-XS	3/4	Stainless Steel Alloy 316L	135, 155, 175, 200 (57, 68, 79, 93)
RA6514	5.6	Pendent	QR	3 mm	1/2	Stainless Steel Alloy 316L	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA6514	5.6	Recessed Pendent	QR	3 mm	1/2	Stainless Steel Alloy 316L	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2042, 2017, 2001, 2015

FM Approval Standard: Select the FM Approvals Standard

Approval Identification: 3056839

Approval Granted: January 17, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6522	8.0	Upright	QR	3 mm-XS	3/4	Stainless Steel Alloy 316L	135, 155, 175, 200, 286 (57, 68, 79, 93, 141, 182)
RA6524	5.6	Upright	QR	3 mm	1/2	Stainless Steel Alloy 316L	135, 155, 175, 200, 286 (57, 68, 79, 93, 141, 182)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657, USA

FM Approvals Class: 2042, 2016, 2001

FM Approval Standard: Select the FM Approvals Standard

Approval Identification: 3056839

Approval Granted: January 17, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA