

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140828-EX3646  
**Report Reference** EX3646-20140829  
**Issue Date** 2014-AUGUST-28

**Issued to:** RELIABLE AUTOMATIC SPRINKLER CO INC  
1470 SMITH GROVE RD  
LIBERTY SC 29657

**This is to certify that  
representative samples of**


RESIDENTIAL AUTOMATIC SPRINKLERS  
SIN RA4835, 1/2 in. NPT, K =4.2, concealed horizontal  
sidewall, fusible solder link type heat responsive element  
rated 165°F, with 135°F rated cover plates. These  
sprinklers have a maximum pressure of 175 psig for wet  
systems only for spacing and flow rates

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1626, Standard for Residential Sprinklers  
ULC/ORD C1626, Canadian National Standard for  
Residential Sprinklers

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as  
being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US  
and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and  
"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL;  
and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

