



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	Connection	Finishes	Temperature Ratings °F (°C)
R601	22.4	Pendent	QR (ESFR) Storage	Fusible	1" NPT or 1" IGS*	Brass	165, 212 (74, 100)
R602	25.2	Pendent	QR (ESFR) Storage	Fusible	1" NPT or 1" IGS*	Brass	165, 212 (74, 100)

**for use with the Style V9 FireLock IGS sprinkler coupling*

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2026, 2028

FM Approval Standard: Class Number 2008 (February 2018)

Approval Identification: PR467662

Approval Granted: 1 February 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062
USA

