



Certificate of Compliance

This certificate is issued for the following equipment:

Quick Response Storage Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	Connection	Finishes	Temperature Ratings °F (°C)
R602	25.2	Pendent	QR (ESFR) Storage	Fusible	1" NPT or 1" IGS*	Brass	165, 212 (74, 100)

**for use with the Style V9 FireLock IGS sprinkler coupling*

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657, USA

FM Approvals Class: 2026
FM Approval Standard: Class Number 2008 (February 2018)

Approval Identification: PR452399

Approval Granted: November 5, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group

