



Certificate of Compliance

This certificate is issued for the following equipment:

Open Water-Spray Nozzles for Fire Protection

Model	Nominal K-Factor (gpm/(psi) ^{1/2})	Nominal Spray Angle (Degrees)	NPT (in.)	Finishes
MV	1.2, 1.8, 2.3, 3.0, 4.1, 5.6, 7.2	65, 80, 95, 110, 125, 140, 160, 180	1/2	Brass, Electroless Nickel PTFE (ENT)

Nozzles are Approved with optional blow-off plug

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2025

FM Approval Standard: Class Number 2021/2025 (February 2010)

Approval Identification: PR459587

Approval Granted: 14 April 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in black ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062
USA

