

Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
R603	28.0	Pendent	QR (ESFR) Storage	Fusible	1	Brass	165, 212 (74, 100)
R604	28.0	Pendent	QR (ESFR) Storage	Fusible	1	Brass	165, 212 (74, 100)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2035

FM Approval Standard: Class Number 2008 (November 2024) and Draft Performance Requirements for Quick-Response Standard-Coverage Pendent Storage Automatic Sprinklers (also referred to as Pendent Suppression Mode Sprinklers) with a Nominal Discharge Coefficient of 28.0 gal/min/(psi)^{1/2} [400 L/min/(bar)^{1/2}] (April 8, 2019)

Approval Identification: PR466977

Approval Granted: December 4, 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062 USA

